

CERTIFICATE

It is certified that the water Sample submitted by HARIRAM GATTANI MEMORIAL JAY BHARAT ENGLISH MEDUIM SCHOOL, NEAR NETAJI CHOWK, AKALTARA ROAD, JANJGIR DISTT. JANJGIR-CHAMPA, CHHATTISGARH is inspected the on 18.02.2020 and found that the sample is safe for drinking purpose.

Encl- Water sample testing Report Enclosed


Executive Engineer
P.H.E.Division
Janjgir-Champa(C.G.)

To

Mr. Prashanta Kumar Padhan

PRINCIPAL

HARIRAM GATTANI MEMORIAL JAY BHARAT
ENGLISH MEDUIM SCHOOL, NEAR NETAJI
CHOWK, AKALTARA ROAD, JANJGIR DISTT.
JANJGIR-CHAMPA , CHHATTISGARH

FORMA FOR WATER ANALYSIS REPORT (ON PAYMENT BASIS)

STRICT LAB JANJGIR-CHAMPA (C.G.)


Principal

1. DATE OF EXAMINATION : 18-02-20. Harisam Gattani memo.
2. SAMPLE DETAILS : Jay Bharat English Medium School
3. PURPOSE OF TEST REPORT : Janjgir ① campus R.O. water
- (PARAMETERS REQUIRED) : ② -r. Ground Borewell P/P m.

Sl. No.	PARAMETERS	SAMPLE NO.					VALUE
		1.	2.	3.	4.	5.	
i	PH	7.90	7.34				
ii	COLOUR	0.0	0.0				
iii	TURBIDITY	2.27	2.67				
iv	CONDUCTIVITY	377	1653				
v	TDS	188	826				
vi	TOTAL HARDNESS	96	260				
vii	ALKALINITY, as CaCO ₃	70	256				
viii	CHLORIDE	20	300				
ix	NITRATE	0.0	0.0				
x	SULPHATE	-	-				
xi	IRON	0.0	0.0				
xii	FLOURIDE	0.0	0.0				
xiii	RESIDUAL CHLORINE	0.0	0.0				
ixv	PRESENCE OF COLIFORM	24 hrs 0.0	0.0				
		48 hrs 0.0	0.0				
xv	ANY OTHER T / D	Uncl	Uncl				

Remin Botts Water Samples are fit for Drinking Purpose.


ASSISTANT ENGINEER
P.H.E. SUB DN. CHAMPA (C.G.)


CHEMIST/
INCHARGE LABORATORY